

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF0502	VOLTS:	208 1P	230 1P	
TAG: CE/KFCEH0501N05	HTR WATTS:	3750	4600	
CE0501N05	HTR AMPS:	18.0	20.0	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
FA4B/FB4B/FC4C,FB4C,FY5B 018-036	26.0	30	28.4	30
PF1MN/PF4MN 018-036,FX4C/FC4D 018-036	26.0	30	28.4	30
FY4A/FA4C/FX4B 018-036,FV4B 002-003	26.0	30	28.4	30
FK4D 001-002,FE4A/FE5A/40FKA 002,FX4A 030-036	26.0	30	28.4	30
FK4C 001-006	26.7	25	29.0	30
FA4A/FB4A/FC4B 018-036	26.7	30	29.0	30
FV4B/FV4C 002-006,FX4A,FB4C, FY5B 042-060	31.2	35	33.5	35
FA4B/FB4B/FC4C/FX4C/FC4D/FX4B/FY4A/FA4C 042-060	31.2	35	33.5	35
PF1MN/PF4MN 037-061,FK4D/FE4A/FE5A/40FKA 003-006	31.2	35	33.5	35
FA4A/FB4A/FC4B 042-060,FH4A 001-004	31.2	40	33.5	40
FX4D 018-037	26.0	30	28.4	30
FX4D 042-061	31.2	35	33.5	35
FH4B,FH4C 001-002 / FZ4A 024-036	26.0	30	28.4	30
FH4B,FH4C 003-004 / FZ4A 048-061	31.2	35	33.5	35

