

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF0602	VOLTS:	208-1P	230-1P
	HTR WATTS:	4500	5520
	HTR AMPS:	21.6	24.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
FA4A 018-070	33.9	35	36.9	40
FB5A 018-070	33.9	35	36.9	40
PF1MN 018-061, PF4MN 018-061, FX4D 019-061	35.5	40	38.5	40
FB4B, FC4C, FC4D, FA4B 018-070/FV4C 002-006	35.5	40	38.5	40
FH4A 001-004/FK4C 001-006	35.5	40	36.9	40
FX4A, FX4C, FC4D, FB4C, FY4A 018-060	35.5	40	38.5	40
FV4A, FV4B 002-006/FA4C, FY4A 018-060	35.5	40	38.5	40
40FKA, FK4D 001-006	35.5	40	38.5	40
FE4A, FE5A 002-006	35.5	40	38.5	40
FB4A, FC4B 018-070	33.9	35	36.9	40
FX4B 030-060/FH4B, FH4C 001-004	35.5	40	38.5	40

