

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF0802B		VOLTS:	208 1P	230 1P	
TAG: CE/ KFCEH1001C08/ 2501C08		HTR WATTS:	6000	7360	
CE1001C08/CE2501C08		HTR AMPS:	28.8	32.0	
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
	FA4A 018-070	42.9	45	46.9	50
	FB5A 018-070	42.9	45	46.9	50
	PF1MN 018-061,PF4MN 018-061,FX4D 019-061	44.7	45	48.5	50
	FB4B,FC4C,FC4D,FA4B 018-070/FV4C 002-006	44.7	45	48.5	50
	FH4A 001-004/FK4C 001-006	42.9	45	46.9	50
	FX4A,FX4C,FC4D,FB4C,FY5B 018-060	44.7	45	48.5	50
	FV4A,FV4B 002-006 / FA4C,FY4A 018-060	44.7	45	48.5	50
	40FKA,FK4D 001-006	44.7	45	48.5	50
	FE4A,FE5A 002-006	44.7	45	48.5	50
	FB4A,FC4B 018-070	42.9	45	46.9	50
	FX4B 030-060/FH4B,FH4C 001-004	44.7	45	48.5	50
	FZ4A 024-061	44.7	45	48.5	50

