

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

| | | |
|--|-------------------|-------------|
| MODEL NO: WKF0805A | VOLTS: | 480 3P |
| | HTR WATTS: | 8000 |
| SINGLE POINT | HTR AMPS: | 9.6 |
| EQUIPMENT MODEL NO | MCA | MOCP |
| FA4A,FB4A 024-070 | 16.25 | 20 |
| PF1MNA 024-071/ PF4M 024-071 | 17.31 | 20 |
| FX4A,FX4B 030-060 | 16.25 | 20 |
| FB5A 024-070 | 16.25 | 20 |
| FK4C,FV4A FV4C,FV4B, FE4A, FE5A 002-006 | 16.25 | 20 |
| 40FKA,FK4D 002-006 | 17.31 | 20 |
| FH4A 002-004 | 17.31 | 20 |
| FC4B 024-070 | 16.25 | 20 |
| FC4D,FX4C,FX4D 018-030 | 13.75 | 15 |
| FC4D,FX4C 036-042, FX4D 31-43 | 14.63 | 15 |
| FC4D,FX4C 048-060, FX4D 49-61 | 15.75 | 20 |
| FY4A,FA4C 018-060 / FA4B, FB4B, FC4C 018-070 | 18.5 | 20 |
| FB4C 018-060, FH4C 001-004 | 15.75 | 20 |
| FY5B 018-060 | 15.25 | 20 |

