

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF0902C	VOLTS:	208 1P	230 1P	
TAG: SIM TO: KFCEH1401N09/ 2901N09	HTR WATTS:	6750	8280	
CE1401N09/CE2901N09	HTR AMPS:	32.5	36.0	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
PF1MN,PF4MN 036-061	49.5	50	53.5	60
FV4B,FE4A,FE5A,FV4C 002-006 /FH4B,FH4C 002-004	49.5	50	53.5	60
FK4D 001-006,FA4B,FB4B,FC4C 036-070	49.5	50	53.5	60
FA4A,FB4A,FC4B 030-070,FB5A 036-070	47.9	50	51.9	60
FH4A 002-004,FK4C 001-006 / FZ4A 036-061	47.9	50	51.9	60
FX4A,FX4C,FX4D,FC4D,FY4A,FA4C,FB4C,FY5B 036-060	49.5	50	53.5	60
FX4B 030-060,FV4A,40FKA 001-006	49.5	50	53.5	60
3 PHASE APPLICATION				
PF1MN,PF4MN 036-061,FV4B,FV4C,FE4A,FE5A 002-006	32.0	35	34.5	35
FK4D 001-006,FA4B,FB4B,FC4C 036-070/FH4B 002-004	32.0	35	34.5	35
FA4A,FB4A,FC4B 030-070,FB5A 036-070	30.4	35	32.9	35
FH4A 002-004,FK4C 001-006 / FZ4A 036-061	30.4	35	32.9	35
FX4A,FX4C,FX4D,FC4D,FY4A,FA4C,FB4C,FY5B 036-060	32.0	35	34.5	35
FX4B 030-060,FV4A,40FKA 001-006 /FH4C 002-004	32.0	35	34.5	35

