

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

| | | | | |
|--|-------------------|-------------|------------|-------------|
| MODEL NO: WKF1002 | VOLTS: | 208 1P | 230 1P | |
| TAG: CE/ KFCEH0901N10 | HTR WATTS: | 7500 | 9200 | |
| CE0901N10 | HTR AMPS: | 36.1 | 40.0 | |
| EQUIPMENT MODEL NO | MCA | MOCP | MCA | MOCP |
| FA4A 018-070 | 52.2 | 60 | 56.9 | 60 |
| FB5A 018-070 | 52.2 | 60 | 56.9 | 60 |
| FB4B,FC4C,FC4D,FA4B 018-070/FV4C 002-006 | 53.8 | 60 | 58.5 | 60 |
| FH4A 001-004/FK4C 001-006 | 52.2 | 60 | 56.9 | 60 |
| FX4A,FX4C,FC4D,FB4C,FY5B 018-060 | 53.8 | 60 | 58.5 | 60 |
| FV4A,FV4B 002-006/FA4C,FY4A 018-060 | 53.8 | 60 | 58.5 | 60 |
| 40FKA,FK4D 001-006 | 53.8 | 60 | 58.5 | 60 |
| PF1MN 018-061,PF4MN 018-061,FX4D 019-061 | 53.8 | 60 | 58.5 | 60 |
| FB4A,FC4B 018-070 | 52.2 | 60 | 56.9 | 60 |
| FE4A,FE5A 002-006 | 52.2 | 60 | 56.9 | 60 |
| FX4B 030-060/FH4B,FH4C 001-004 | 53.3 | 60 | 58.5 | 60 |
| FZ4A 024-061 | 53.8 | 60 | 58.5 | 60 |
| | | | | |
| | | | | |

