

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF1202BS	VOLTS:	208-1P	230-1P
	HTR WATTS:	9000	11040
	HTR AMPS:	43.2	48.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
FV4C,FV4B,FE4A,FE5A,40FKA,FV4A 002-006	62.5	70	68.5	70
FA4B,FB4B,FC4C 024-070	60.5	70	66.5	70
PF1MN,PF4MN 024-061	61.5	70	67.5	70
FX4C,FX4D,FC4D,FB4C,FY5B 024-060	61.5	70	67.5	70
FK4D,FK4C 001-006	62.5	70	68.5	70
FY4A,FA4C 024-060	60.5	70	66.5	70
FA4A,FB4A,FC4B 024-070	62.5	70	68.5	70
FH4A,FH4B,FH4C 001-004	60.8	70	66.8	70
FX4A,FX4B 030-060	60.5	70	66.5	70
FB4B 024-060	61.5	70	67.5	70

