

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF1502	VOLTS:	208 1P	230 1P	
TAG: SIM TO: KFCEH1501F15/ 3001F15	HTR WATTS:	11250	13800	
CE1501F15/CE3001F15	HTR AMPS:	36.2-18.1	40.0-20.0	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
FA4A,FB4A,FC4B,FB5A 024-070	52.2-22.5	60-25	56.9-25	60-25
FH4A 001-004,FK4C,FV4A 001-006	52.2-22.5	60-25	56.9-25	60-25
FE4A,FE5A,FV4B,FV4C 002-006	53.8-22.7	60-25	58.5-25	60-25
FX4C,FX4D,FC4D,FY4A,FA4C,FB4C, FY5B 024-060	53.8-22.7	60-25	58.5-25	60-25
FX4A,FX4B 030-060	53.8-22.7	60-25	58.5-25	60-25
40FKA,FK4D 001-006	53.8-22.57	60-25	58.5-25	60-25
FA4B,FB4B,FC4C 024-070	53.8-22.7	60-25	58.5-25	60-25
PF1MN,PF4MN 024-061	53.8-22.7	60-25	58.5-25	60-25
FH4B,FH4C 001-004	53.8-22.7	60-25	58.5-25	60-25
FZ4A 024-061	53.8-22.7	60-25	58.5-25	60-25

