

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF2002B	VOLTS:	208 1P	230 1P	
TAG: SIM TO: KFCEH1901C20/ 3301C20	HTR WATTS:	15000	18400	
CE1901C20/CE3301C20	HTR AMPS:	36.1-36.1	40.0-40.0	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
PF1MN,PF4MN 030-061,FV4B,FV4C,FE4A,FE5A 002-006	53.8-45.3	60-50	58.5-50.0	60-50
FK4D 001-006,FA4B,FB4B,FC4C 030-070	53.8-45.3	60-50	58.5-50.0	60-50
FY4A,FA4C,FX4B,FX4C,FX4D,FC4D,FB4C,FY5B 030-061	53.8-45.3	60-50	58.5-50.0	60-50
FV4A,40FKA 001-006	53.8-45.3	60-50	58.5-50.0	60-50
FX4A 030-060,FB5A 030-070	52.2-45.3	60-50	56.9-50.0	60-50
FH4A 002-004,FK4C 001-006	52.2-45.3	60-50	56.9-50.0	60-50
FA4A,FB4A,FC4B 030-070	52.2-45.3	60-50	56.9-50.0	60-50
FH4B,FH4C 002-004	53.8-45.3	60-50	58.5-50.0	60-50
FZ4A 048-061	53.8-45.3	60-50	58.5-50.0	60-50

