

CROSS REFERENCE

JANITROL / GOODMAN

PC / PCK 024-060 PACKAGED AIR CONDITIONER (10 SEER)
 PCJ / PCKJ 024-060 PACKAGED AIR CONDITIONER (12 SEER)
 PH / PHK 024-060 PACKAGED HEAT PUMP (10 SEER)
 PCH / PHKJ 024-060 PACKAGED HEAT PUMP (12 SEER)

Warren Model No.	Janitrol/Goodman Model No.	KW	Voltage/Phase	Fits
WJA0502	HK05-1	4.8	240/1Ø	024 thru 060
WJA0752	HK08-1	7.3	240/1Ø	024 thru 060
WJA1002	HK10-1	9.8	240/1Ø	024 thru 060
WJA1502	HK15-1	14.8	240/1Ø	030 thru 060
WJA2002	HK20-1	19.6	240/1Ø	036 thru 060
WJA0504	HK05-3	4.8	240/3Ø	024 thru 060
WJA1004	HK10-3	9.8	240/3Ø	024 thru 060
WJA1504	HK15-3	15.0	240/3Ø	030 thru 060
WJA2004	HK20-3	19.6	240/3Ø	036 thru 060
WJA1505	HK15-4	15.0	460/3Ø	030 thru 060
WJA2005	HK20-4	19.6	460/3Ø	036 thru 060

WARREN TECHNOLOGY

2050 W 73 ST • PO BOX 5347 • HIALEAH, FL 33016-9912 • TEL 305-556-6933 • FAX 305-557-6157

Website: www.warrenhvac.com

N:\WORKSHEETS-NEW\GODMAN 3-1-06

CROSS REFERENCE

JANITROL / GOODMAN

PC / PCK 024-060 PACKAGED AIR CONDITIONER (10 SEER)

PCJ / PCKJ 024-060 PACKAGED AIR CONDITIONER (12 SEER)

PH / PHK 024-060 PACKAGED HEAT PUMP (10 SEER)

PCH / PHKJ 024-060 PACKAGED HEAT PUMP (12 SEER)

Warren Model No.	Janitrol/Goodman Model No.	KW	Voltage/Phase	Fits
WJA0502T	N/A	4.8	240/1ø	024 thru 060
WJA0752T	N/A	7.3	240/1ø	024 thru 060
WJA1002T	N/A	9.8	240/1ø	024 thru 060
WJA1502	HK15-1	14.8	240/1ø	030 thru 060
WJA2002	HK20-1	19.6	240/1ø	036 thru 060
WJA0504	HK05-3	4.8	240/3ø	024 thru 060
WJA1004	HK10-3	9.8	240/3ø	024 thru 060
WJA1504	HK15-3	15.0	240/3ø	030 thru 060
WJA2004	HK20-3	19.6	240/3ø	036 thru 060
WJA1505	HK15-4	15.0	460/3ø	030 thru 060
WJA2005	HK20-4	19.6	460/3ø	036 thru 060

T= Terminal block connection in place of circuit breakers

WARREN TECHNOLOGY

2050 W 73 ST • PO BOX 5347 • HIALEAH, FL 33016-9912 • TEL 305-556-6933 • FAX 305-557-6157

Website: www.warrenhvac.com