

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WKS0605A	<b>VOLTS:</b>		480-3P	
	<b>HTR WATTS:</b>		6000	
	<b>HTR AMPS:</b>		7.2	
<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B			10.2	15
ARPT 36C, 36D / ARUF 36C, 37C, 37D, 42C, 43C, 49C			10.9	15
ARPT 42D, 48D / ARUF 43D, 47D, 48D, 49D			11.2	15
ARPT 60D / ARUF 60D, 61D			11.9	15
AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B			11.4	15
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D, 39C			12.3	15
AVPTC / DVPTC 42C, 42D, 48C, 49C, 49D			12.3	15
AVPTC / DVPTC 48D, 59C, 59D, 60D, 61D			13.3	15
ASPT 24B / ASUF 29B			10.4	15
ASPT 30C, 36C / ASUF 39C			11.0	15
ASPT 42D			12.0	15
ASUF 48D, 60D, 61D / ASUF 59D			13.2	15
ASUF 49C			12.4	15
080218R				

