

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS0804	VOLTS:	208-3P	240-3P
	HTR WATTS:	6000	8000
Page 1 of 2	HTR AMPS:	16.7	19.2

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B	24	25	27	30
ARPT 36C / ARUF 36C,37C,37D,42C,43C,49C	25	25	28	30
ARPT 36D	25	25	28	30
ARPT 42D, 48D / ARUF 43D,47D,48D,49D	26	30	29	30
ARPT 60D / ARUF 60D,61D	27	30	30	30
AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B	26	30	29	30
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D	28	30	31	35
AVPTC / DVPTC 39C, 42C, 42D, 48C, 49C, 49D	28	30	31	35
AVPTC / DVPTC 48D, 59C,59D, 60D, 61D	30	30	33	35
ASPT 24B / ASUF 29B	24	25	27	30
ASPT 30C, 36C / ASUF 39C	25	25	28	30
ASPT 42D	27	30	31	35
080318R				

