

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

| | | | |
|---|-------------------|-------------|------------------------|
| MODEL NO: WKS0805 | VOLTS: | | 480-3P |
| | HTR WATTS: | | 8000 |
| | HTR AMPS: | | 9.62 |
| EQUIPMENT MODEL NO | MCA | MOCP | MCA MOCP |
| ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B | | | 12.0 15 |
| ARPT 36C,36D / ARUF 36C,37C,37D,42C,43C,49C | | | 12.0 15 |
| ARPT 42D,48D / ARUF 43D,47D,48D,49D | | | 12.0 15 |
| ARPT 60D / ARUF 60D,61D | | | 12.0 15 |
| AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B | | | 12.0 15 |
| AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D | | | 12.0 15 |
| AVPTC / DVPTC 39C, 42C, 42D, 48C, 49C, 49D | | | 12.0 15 |
| AVPTC / DVPTC 48D, 59C, 59D, 60D, 61D | | | 12.0 15 |
| ASPT 24B / ASUF 29B | | | 12.0 15 |
| ASPT 30C, 36C / ASUF 39C | | | 17.0 15 |
| ASPT 42D | | | 12.0 15 |
| ASUF 48D, 60D, 61D / ASUF 59D | | | 12.0 15 |
| ASUF 49C | | | 12.0 15 |
| 080318R | | | |

