

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS0805A	VOLTS:		480-3P	
	HTR WATTS:		8000	
	HTR AMPS:		9.62	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B			13.2	15
ARPT 36C,36D / ARUF 36C,37C,37D,42C,43C,49C			13.9	15
ARPT 42D, 48D / ARUF 43D,47D,48D,49D			14.2	15
ARPT 60D / ARUF 60D,61D			14.9	15
AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B			14.5	15
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D			15.3	15
AVPTC / DVPTC 39C, 42C, 42D, 48C, 49C, 49D			15.3	15
AVTPC / DVPTC 48D, 59C, 59D, 60D, 61D			16.3	20
ASPT 24B / ASUF 29B			13.4	15
ASPT 30C, 36C / ASUF 39C			14.0	15
ASPT 42D			15.1	20
ASPT 48D, 60D, 61D / ASUF 59D			16.2	20
ASUF 49C			15.4	20
080318R				

