

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1002B	VOLTS:	208 1P	240 1P
TAG: HKSC10XC	HTR WATTS:	7200	9600
Page 1 of 2	HTR AMPS:	34.7	40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B	46	50	53	60
ARPT 36C / ARUF 36C,37C,37D,42C,43C,49C	48	50	54	60
ARPT 36D	48	50	54	60
ARPT 42D, 48D / ARUF 43D,47D,48D,49D	48	50	55	60
ARPT 60D / ARUF 60D,61D	50	50	56	60
AVPTC / DVPTC 24B, 25, 30C, 33C, 35B	48	50	55	60
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D, 39C	50	50	57	60
AVPTC / DVPTC 42C, 42D, 48C, 49C, 49D	50	50	57	60
AVPTC / DVPTC 48D, 59C, 59D, 60D, 61D	52	60	59	60
ASPT 24B / ASUF 29B	46	50	53	60
ASPT 30C, 36C / ASUF 39C	47	50	54	60
ASPT 42D	49	50	56	60
080218R				

