

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WKS1004	<b>VOLTS:</b>	208 3P	240 3P
	<b>HTR WATTS:</b>	6750	9000
page 1 of 2	<b>HTR AMPS:</b>	18.7	21.7

<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
ARPT 18B,24B,30B / ARUF 18B,24B,25B,30B,29B,31B	26	30	30	30
ARPT 36C / ARUF 36C,37C,37D,42C,43C,49C	28	30	31	35
ARPT 36D	28	30	31	35
ARPT 42D,48D / ARUF 43D,47D,48D,49D	29	30	32	35
ARPT 60D / ARUF 60D,61D	30	30	33	35
AVPTC 24B, 25B,30C,33C,35B	29	30	32	35
AVPTC 29B,31C,36C,37B,37C,37D,39C,42D,48D,49C,49D	30	30	34	35
AVPTC 60D,61D	32	35	36	40
ASPT 24B / ASUF 29B	27	30	30	30
ASPT 30C,36C / ASUF39C	28	30	32	35
ASPT 42D	30	30	34	35
ASPT 48D,60D / ASUF 59D	32	35	36	40
ASUF 49C	31	35	34	35
072618R				

