

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1005	VOLTS:		480-3P	
	HTR WATTS:		9600	
	HTR AMPS:		11.6	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 24B,30B / ARUF 18B,24B,25B,29B,30B,31B			14.5	15
ARPT 36C,36D / ARUF 36C,37C,37D,42C,43C,49C			14.5	15
ARPT 42D,48D / ARUF 43D,47D,48D,49D			14.5	15
ARPT 60D / ARUF 60D,61D			14.5	15
AVPTC / DVPTC 24B, 25B30C,33C,35B			14.5	15
AVPTC / DVPTC 29B,31C,36C,37B,37C,37D,39C			14.5	15
AVPTC / DVPTC 42D,48C,48D,49C,49D			14.5	15
AVPTC / DVPTC 60D,61D			14.5	15
ASPT 24B / ASUF 29B			14.5	15
ASPT 30C, 36C / ASUF 39C			14.5	15
ASPT 42D			14.5	15
ASPT 48D, 60D, 61D / ASUF 59D			14.5	15
ASUF 49C			14.5	15
072618R				

