

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1501B/ WKS2002B		VOLTS:	208 1P	240 1P
TAG: HKSC19CA, HKSC20DA/		HTR WATTS:	14400	19200
HKSC19CB, HKS20DB		HTR AMPS:	46-23	53-27
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 36C	48-44	50-45	54-50	60-60
ARPT 36D	48-44	50-45	54-50	60-60
ARPT 42D, 48D	48-44	50-45	55-50	60-60
ARPT 60D	50-44	50-45	56-50	60-60
ARUF 36C,37C,37D	48-44	50-45	54-50	60-60
ARUF 42C,43C,39C	48-44	50-45	54-50	60-60
ARUF 48D	48-44	50-45	55-50	60-60
ARUF 60D	50-44	50-45	56-50	60-60

