

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF0502	VOLTS:	208 1P	230 1P
TAG: EHK05AKN1 / EHK05AKN	HTR WATTS:	3750	4600
page 1 of 2	HTR AMPS:	18.0	20.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
EBP1800-3600, A/B WAH(M,T) 18-36, FXM4X 18-36	25.9	30	28.4	30
EBP4200-6000, A/B WAH(M,T) 42-60, FXM4X 42-60	31.0	35	33.5	35
EBX/V2400A-3600A, FCM4X 24-36 WAP(M,T) 18-36	25.9	30	28.4	30
EBX/V4200A-6000A, FCM4X 48, 60 WAP(M,T) 42-60	31.0	35	33.5	35
FEM,FSU,FSM,FVM (2,4) 1800A - 3600A	25.9	30	28.4	30
FEM,FSU,FSM,FVM(2,4) 4200A - 6000A	31.0	35	33.5	35

