

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

| | | | |
|-----------------------------------|-------------------|--------|--------|
| MODEL NO: WKF0902C | VOLTS: | 208 1P | 230 1P |
| TAG: EHK09AKCN1/ EHC09AKCN | HTR WATTS: | 6750 | 8280 |
| | HTR AMPS: | 32.5 | 36.0 |

| EQUIPMENT MODEL NO | MCA | MOCP | MCA | MOCP |
|--|------------|-------------|------------|-------------|
| | 1P/3P | 1P/3P | 1P/3P | 1P/3P |
| EBP1800A-6000A WAH(M,T) 36-60, FXM4X 36-60 | 32/49.1 | 35/50 | 34.5/53.5 | 35/60 |
| EBP1800B-6000B, WAP(M,T) 36-60 | 32/49.1 | 35/50 | 34.5/53.5 | 35/60 |
| EBX2400A-6000A, FCM4X 36-60 | 32/49.1 | 35/50 | 34.5/53.5 | 35/60 |
| EBV2400A-6000A | 32/49.1 | 35/50 | 34.5/53.5 | 35/60 |
| FEM, FSM, FSU,FVM (2,4) 1800A-6000A | 32/49.1 | 35/50 | 34.5/53.5 | 35/60 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

