

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF1504	VOLTS:	208-3P	230-3P
TAG: EHK15AHN	HTR WATTS:	11250	13800
	HTR AMPS:	31.2	39.6

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
EBP3600A-6000A, WAP(M,T) 36-60	47.7	50	51.8	60
EBP3600B-6000B, FXM4X 24-60	47.7	50	51.8	60
EBX3600A-6000A, WAHL 364,424,484,604	47.7	50	51.8	60
EBV3600A-6000A	47.7	50	51.8	60
FEM 3500-6000	47.7	50	51.8	60
FSU,FSM 3500-4850, FCM4X 24-60	47.7	50	51.8	60

