

CROSS REFERENCE

WARREN WLZ SERIES ELECTRIC HEATERS	LENNOX DATE: 2-28-12	LENNOX CBX32M, CBX32MV, CB29M, CB30M, CB30U, CB31MV CBX27UH
---	---------------------------------	--

WLZ SERIES

WARREN MODEL#	LENNOX MODEL#	KW @ 240	FITS	AMPS	STEPS
WLZ0502	ECB29-5	5	024-060	20.0	1
WLZ0502B	ECB29-5CB	5	024-060	20.0	1
WLZ0502BX	ECB29-5CB(X)	5	CBX27UH 018-036	20.0	1
WLZ0502BY	ECB29-5CB(Y)	5	CBX27UH 042-060	20.0	1
WLZ0602	ECB29-6	6	024-060	25.0	2
WLZ0602B	ECB29-6CB	6	024-060	25.0	2
WLZ0802	ECB29-8	8	024-060	33.3	2
WLZ0802BX	ECB29-8CB(X)	8	CBX27UH 018-036	33.3	2
WLZ0802BY	ECB29-8CB(Y)	8	CBX27UH 042-060	33.3	2
WLZ0802B	ECB29-8CB	8	024-060	33.3	2
WLZ0902	ECB29-9	9	024-060	36.7	2
WLZ0902B	ECB29-9CB	9	024-060	36.7	2
WLZ1002	ECB29-10	10	024-060	40.0	2
WLZ1002B	ECB29-10CB	10	024-060	40.0	2
WLZ1252B	ECB29-12.5CB	12.5	030-060	50.0	3
WLZ1252BX	ECB29-12.5CB(X)	12.5	CBX27UH 024-036	50.0	3
WLZ1252BY	ECB29-12.5CB(Y)	12.5	CBX27UH 042-060	50.0	3
WLZ1502B	ECB29-15CB	15	030-060	60.0	3
WLZ1502BX	ECB29-15CB(X)	15	CBX27UH 024-036	60.0	3
WLZ1502BY	ECB29-15CB(Y)	15	CBX27UH 042-060	60.0	3
WLZ2002B	ECB29-20CB	20	042-060	80.0	4

- 'B' DENOTES CIRCUIT BREAKER (S)
- GALVANIZED CONSTRUCTION
 - OVERTEMPERATURE LIMIT PROTECTION
 - ANTI-CYCLING MAGNETIC CONTACTORS PER 5 KW STEPS
 - TIME DELAY BETWEEN STEPS
 - HACR CIRCUIT BREAKERS (B VERSION)

NOTES:

5KW - X = 35 AMP CIRCUIT BREAKER
Y = 40 AMP CIRCUIT BREAKER

8KW - X = 50 AMP CIRCUIT BREAKER
Y = 60 AMP CIRCUIT BREAKER

12.5KW - X = 30 & 45 AMP CIRCUIT BREAKERS
Y = 35 & 45 AMP CIRCUIT BREAKERS

15KW - X = 35 & 60 AMP CIRCUIT BREAKERS
Y = 40 & 60 AMP CIRCUIT BREAKERS

WARREN TECHNOLOGY

2050 W 73 ST * HIALEAH, FL 33016-9912 * TEL (305) 556-6933 * FAX (305) 557-6157

Website: www.warrenhvac.com