

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K0502B	VOLTS:	208 1P	240 1P
TAG: 6HK1650056	HTR WATTS:	3600	4800
PAGE 2 OF 2	HTR AMPS:	17.3	20.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AP 42C	25.1	30	27.4	30
AP 48C, 48D	25.3	30	27.5	30
AP 60C, 60D	26.8	30	29.0	30
AE 18B, 24B, 30B	25.8	30	28.0	30
AE 36B, 36C, 42C	27.6	30	29.9	30
AE 48C, 48D, 60C, 60D	30.1	35	32.4	35
AVC 18B, 24B, 30B	25.4	30	27.5	30
AVC 36B, 36C, 42C	27.9	30	29.5	30
AVC 48C, 48D, 60C, 60D	30.8	35	32.7	35
AVV 25B, 37B, 37C, 38C	27.9	30	29.5	30
AVV 49C, 49D, 50D, 61C, 61D	30.8	35	32.7	35
RFCX 18BE, 22BE, 24BE, 30BE	25.2	28.5	30	30
RFCX 34CE, 36CE, 42DE	26.8	30.1	30	35
RFCX48DE, 60DE	29.2	32.5	30	35

