

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

|                           |                   |  |        |
|---------------------------|-------------------|--|--------|
| <b>MODEL NO:</b> W6K0805A | <b>VOLTS:</b>     |  | 480 3P |
|                           | <b>HTR WATTS:</b> |  | 7680   |
| PAGE 1 OF 2               | <b>HTR AMPS:</b>  |  | 9.24   |

| <b>EQUIPMENT MODEL NO</b> | <b>MCA</b> | <b>MOCP</b> | <b>MCA</b> | <b>MOCP</b> |
|---------------------------|------------|-------------|------------|-------------|
| AHR 18B, 24B              |            |             | 13.3       | 15          |
| AHR 30B, 36B              |            |             | 13.9       | 15          |
| AHR 42C, 48D, 60D         |            |             | 13.9       | 15          |
| AHE 18B, 22B, 24B, 30B    |            |             | 13.3       | 15          |
| AHE 34C, 36C, 42D         |            |             | 14.1       | 15          |
| AHE 48D, 60D              |            |             | 15.3       | 20          |
| AP 18B                    |            |             | 12.2       | 15          |
| AP 24B                    |            |             | 12.4       | 15          |
| AP 30B                    |            |             | 12.9       | 15          |
| AP 36B                    |            |             | 13.2       | 15          |
| AP 36C, 37C               |            |             | 12.9       | 15          |
| AP 42                     |            |             | 13.4       | 15          |
| AP 48C, 48D               |            |             | 13.4       | 15          |
| AP 60C, 60D               |            |             | 14.1       | 15          |

