

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1004	VOLTS:	208 3P	240 3P
TAG: 6HK36501025	HTR WATTS:	7200	9600
PAGE 1 OF 2	HTR AMPS:	20.0	23.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHR 18B, 24B	28.5	30	31.3	35
AHR 30B, 36B	30.1	35	34.0	35
AHR 42C, 48D, 60D	32.5	35	36.4	40
AHE 18B, 22B, 24B, 30B	26.8	30	30.6	35
AHE 34C, 36C, 42D	29.8	30	33.6	35
AHE 48D, 60D	29.8	30	33.6	35
AP 18B	26.4	30	29.4	30
AP 24B	26.8	30	29.4	30
AP 30B	27.9	30	30.5	35
AP 36B	28.3	30	30.9	35
AP 36C, 37C	27.8	30	30.1	35
AP 42C	28.5	30	31.1	35
AP 48C, 48D	28.6	30	31.3	35
AP 60C, 60D	30.1	35	32.8	35

