

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1302B(S)	VOLTS:	208-1P	240-1P
TAG: 6HK16051306	HTR WATTS:	9360	12480
PAGE 1 OF 4	HTR AMPS:	45.0	52.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHR 24B	37.5-20.3	40-25	41.3-22.4	45-25
AHR 30B, 36B	37.5-23.0	40-25	41.3-25.4	45-30
AHR 42C, 48D, 60D	37.5-23.0	40-25	41.3-25.4	45-30
AHE 22B, 24B, 30B	37.5-22.3	40-25	41.3-24.2	45-25
AHE 34C, 36C, 42D	37.5-23.0	40-25	41.3-25.8	45-30
AHE 48D, 60D	37.5-26.3	40-25	41.3-28.2	45-30
SINGLE POINT				
AHR 24B	58.0	60	66.8	70
AHR 30B, 36B	61.0	70	69.8	70
AHR 42C, 48D, 60D	61.0	70	69.8	70
AHE 24B, 30B	59.8	60	66.8	70
AHE 36C, 42D	61.4	70	70.1	80
AHE 48D, 60D	63.8	70	72.5	80

