

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1302B(S)	VOLTS:	208-1P	240-1P
TAG: 6HK16051306	HTR WATTS:	9360	12480
PAGE 3 OF 4	HTR AMPS:	45.0	52.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHV 24B, 30B	22.2-37.6	25-40	24.6-43.3	25-45
AHV 36C, 42D	23.3-37.6	25-40	25.7-43.3	30-45
AHV 48D, 60D	25.4-37.6	30-40	27.8-43.3	30-45
AVV25B, 37B, 37C, 38C	25.0-37.6	25-40	26.4-41.5	30-45
AVV 49C,49D, 50D, 61C, 61D	27.9-37.6	30-40	29.5-41.5	30-45
SINGLE POINT				
AHV 24B, 30B				
AHV 36C, 42D				
AHV 48D, 60D				
AVV 25B, 37B, 37C, 38C	62.7	70	68.1	70
AVV 49C, 49D, 50D, 61C, 61D	65.6	70	71.3	80

