

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

|                           |                   |  |         |
|---------------------------|-------------------|--|---------|
| <b>MODEL NO:</b> W6K1305A | <b>VOLTS:</b>     |  | 480V 3P |
|                           | <b>HTR WATTS:</b> |  | 12500   |
| PAGE 2 OF 2               | <b>HTR AMPS:</b>  |  | 15.0    |

| <b>EQUIPMENT MODEL NO</b> | <b>MCA</b> | <b>MOCP</b> | <b>MCA</b> | <b>MOCP</b> |
|---------------------------|------------|-------------|------------|-------------|
| AP 48C, 48D               |            |             | 20.6       | 25          |
| AP 60C, 60D               |            |             | 21.3       | 25          |
| AE 24B, 30B               |            |             | 20.4       | 25          |
| AE 36B, 36C, 42C          |            |             | 21.1       | 25          |
| AE 48C, 48D, 60C, 60D     |            |             | 22.1       | 25          |
| AVC 24B,30B               |            |             | 20.6       | 25          |
| AVC 36B,36C,42C           |            |             | 21.6       | 25          |
| AVC 48C,48D,60C,60D       |            |             | 23.1       | 25          |
|                           |            |             |            |             |
|                           |            |             |            |             |
|                           |            |             |            |             |
|                           |            |             |            |             |
|                           |            |             |            |             |
|                           |            |             |            |             |

