

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1305A	VOLTS:		480V 3P
	HTR WATTS:		12500
PAGE 1 OF 2	HTR AMPS:		15.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHR 24B			19.6	20
AHR 30B, 36B			21.1	25
AHR 42C, 48D, 60D			21.1	25
AHE 22B, 24B, 30B			20.5	25
AHE 34C, 36C, 42D			21.3	25
AHE 48D, 60D			22.5	25
AHV 24B, 30B			20.2	25
AHV 36C, 42D			20.8	25
AHV 48D, 60D			21.8	25
AP 24B			19.6	20
AP 30B			20.2	25
AP 36B			20.4	25
AP 36C, 37C			20.1	25
AP 42C			20.5	25

