

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> W6K1502B(S)	<b>VOLTS:</b>	208 1P	240 1P
<b>TAG:</b> 6HK16501506	<b>HTR WATTS:</b>	10800	14400
PAGE 4 OF 5	<b>HTR AMPS:</b>	51.9	60.0

<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
AHV 24B,30B	25.1-43.3	30-45	27.9-50.0	30-50
AHV 36C,42D	26.2-43.3	30-45	29.0-50.0	30-50
AHV 48D,60D	28.3-43.3	30-45	31.1-50.0	35-50
MVC 12B,14D	27.9-43.3	30-45	29.6-47.9	30-50
MVC 16C,20D	30.8-43.3	35-45	32.7-47.9	35-50
<b>SINGLE POINT</b>				
AHV 24B,30B	68.4	70	77.9	80
AHV 36C,42D	69.5	70	79.0	80
AE 48D,60D	71.6	80	81.1	90
MVC 12B,14D	71.2	80	77.4	80
MVC 16C,20D	74.0	80	80.5	90

