

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX0505A	VOLTS:		480 - 3P
	HTR WATTS:		4800
page 2 of 2	HTR AMPS:		5.8

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
RH1T 2417 / RH2T 2421			9.0	15
RH1T 3617			9.9	15
RH1T 3621,4821 / RH2T 3621			9.9	15
RH1T 4824,6024 / RH2T 4824,6024			15.1	20
RH1P 1817,2417			8.3	15
RH1P 3017,3617,3621			8.8	15
RH1P 4221,4821,4824,6024			10.5	15
RH1V 2417ST			9.0	15
RH1V 3617ST			9.9	15
RH1V 3621HT,3621MT,4821ST,4821MT,6021ST			9.9	15
RH1V 4824ST,6024ST			11.5	15
RH2V 2421HT			8.3	15
RH2V 3624HT,4824HT,6024HT			10.3	15
R 081617				

