

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX1002(B/X)	VOLTS:	208-1P	240-1P
TAG: RXBH17,24A-10J / RXBH-1724A(B)(C)10J	HTR WATTS:	7200	9600
Page 2 of 2	HTR AMPS:	34.6	40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
RH1V 2417 / RHMV 2417	47	50	54	60
RH1V 3617 / RHMV 2421 HEAC	49	50	56	60
RH1V 3621,4821, 6021	49	50	56	60
RH1V 4824,6024	52	60	59	60
RH2V 2421 / RHMV 2421 MEAC	46	50	53	60
RH2V 3624,4824,6024	50	50	57	60
RHMV 3617	48	50	55	60
RHMV 6021,6024	50	50	57	60
FH 2417 TTS	47	50	54	60
FH 3617,3621,4821,6021 TTS	49	50	56	60
FH 4824,6024 TTS	49	50	56	60
FH 1817,2417 TPS	46	50	53	60
FH 3017,3617,3621 TPS	47	50	54	60
FH 4221,4821,4824,6024 TPS	50	50	57	60

