

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX1302S(B/X)	VOLTS:	208-1P	240-1P
TAG: RXBH-1724A13J	HTR WATTS:	9375	12500
PAGE 2 OF 4	HTR AMPS:	15.0-30.1	17.4-34.7

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DUAL CIRCUIT				
RHLA/RHLL/UHLA/UHLL 42-48 (21)	24-38	25-40	27-44	30-45
RHLA/RHLL/UHLA/UHLL 18-24(17)	21-38	25-40	24-44	25-45
RHLA/RHLL/UHLA/UHLL 30-36(17)	23-38	25-40	26-44	30-45
RHKA/RHKL 18-24(17)	22-38	25-40	25-44	25-45
RHKA/RHKL 30-36(17)	23-38	25-40	26-44	30-45
RHSA/RHSL/UHSA/UHSL 18-24(17)	21-38	25-40	24-44	25-45
RHSA/RHSL/UHSA/UHSL 30-36(17)	22-38	25-40	25-44	25-45
RHLP 24(17)	21-38	25-40	24-44	25-45
RHLP 36(17)	23-38	25-40	26-44	30-45
RHML 24(21)	21-38	25-40	24-44	25-45
HFE 18-24(17)	21-38	25-40	24-44	25-45
HFE 30-36(17)	23-38	25-40	26-44	30-45

