

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX1502S(B/X)	VOLTS:	208-1P	240-1P	
TAG: RXBH17, 24A-15J / RXBH-1724A15J	HTR WATTS:	10800	14400	
PAGE 2 OF 4	HTR AMPS:	17.3-34.6	20.0-40.0	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DUAL CIRCUIT				
RHLA/RHLL/UHLA/UHLL 30-36 9(17)/HFE 30-42(17, 21)	25-44	25-45	29-50	30-50
RHLA/RHLL/UHLA/UHLL 42-48(21)	27-44	30-45	30-50	30-50
RHLA/RHLL/UHLA/UHLL 48-60(24)/HFE 48-60(21, 24)	28-44	30-45	31-50	35-50
RHSA/RHSL/UHSA/UHSL 30-36(17, 21)	25-44	25-45	29-50	30-50
RHSA/RHSL/UHSA/UHSL 42-48(21, 24)	29-44	30-45	32-50	35-50
RHKA/RHKL 30-48(17, 21)/RHPL 36-48 (24)	27-44	30-45	30-50	30-50
RHKA/FHKL 48-60(24)/RHPL 60(24)/RHPN 36-60(24)	28-44	30-45	31-50	35-50
RH1T 3617	26-44	30-45	29-50	30-50
RH1T 3621,4821 / RH2T 3621	27-44	30-45	30-50	30-50
RH1T 4824,6024 / RH2T 4824,6024	28-44	30-45	31-50	35-50
RH1P 3017,3617,3621	25-44	25-45	29-50	30-50
RH1P 4221,4821,4824	29-44	30-45	32-50	35-50
RH1P 6024	29-44	30-45	32-50	35-50

