

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX1502S(B/X)	VOLTS:	208-1P	240-1P
TAG: RXBH17, 24A-15J / RXBH-1724A15J	HTR WATTS:	10800	14400
PAGE 1 OF 4	HTR AMPS:	51.9	60.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
SINGLE CIRCUIT				
RHLA/RHLL/UHLA/UHLL 30-48(17,21)/HFE 30-42(17,21)	70	70	80	80
RHLA/RHLL/UHLA/UHLL 48-60(24)	71	80	81	90
RHPN 036-060(24)/RHPL 48-60(24)	72	80	82	90
RHKB/RHKL 30-48(A,21)	70	70	80	80
RHKA/RHKL 48-60(24)/HFE 48-60(21,24)	71	80	81	90
RHSA/RHSL/UHSA/UHSL 30-36(17,21)	68	70	79	80
RHSA/RHSL/UHSA/UHSL 42-48(21,24)	72	80	82	90
RH1T 3617	69	70	79	80
RH1T 3621,4821 / RH2T 3621	70	70	80	80
RH1T 4824,6024 / RH2T 4824,6024	71	80	81	90
RH1P 3017,3617, 3621	68	70	79	80
RH1P 4221,4821,4824	72	80	82	90
RH1P 6024	72	80	82	90

