

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

| | | | | |
|-----------------------------|-------------------|-------------|------------|-------------|
| MODEL NO: WRX1804(B) | VOLTS: | 208-3P | 240-3P | |
| TAG: RXBH-17,24A-18C | HTR WATTS: | 12800 | 17000 | |
| | HTR AMPS: | 35.5 | 41.0 | |
| EQUIPMENT MODEL NO | MCA | MOCP | MCA | MOCP |
| UHLA/LL 30-36(17) | 48.0 | 50 | 55.0 | 60 |
| UHSA/SL 30-36(17,21) | 48.0 | 50 | 55.0 | 60 |
| UHLA/LL 42-48(21) | 50.0 | 50 | 56.0 | 60 |
| UHSA/SL 42-60(21,24) | 50.0 | 50 | 57.0 | 60 |
| UHLA/LL 48-60(24) | 51.0 | 60 | 57.0 | 60 |
| RHKA 30-36(17) | 49.0 | 50 | 56.0 | 60 |
| RHKA 42-60(21,24) | 50.0 | 50 | 57.0 | 60 |
| RHMV 2421HEAC | 50.0 | 50 | 57.0 | 60 |
| RHMV 3617SEAC | 49.0 | 50 | 56.0 | 60 |
| RHMV 6021SEAC | 51.0 | 60 | 58.0 | 60 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

