

RUPP MANAGEMENT DIVISION OF CAPTIVEAIRE

DATE: 06-01-04

STANDARD FEATURES:

- * POSITION 4
- * MAGNETIC DE-ENERGIZING CONTACTORS
- * FAN INTERLOCK RELAY (120 VOLT)
- * BAR CODE LABEL
- * AIR PRESSURE SWITCH
- * CERTIFICATION LABEL - U.L.
- * TRANSFORMER CLASS II
- * CIRCUIT FUSING PER U.L. AND N.E.C.
- * DOOR-INTERLOCK DISCONNECT SWITCH (NON-FUSED)
- * STEP CONTROLLER
- * DUCT THERMOSTAT FOR STEP CONTROLLER
- * HINGED LID

- * **ORDER BY WARREN'S TAG NUMBER OR RUPP'S MODEL NUMBER**
- * **STANDARD PRODUCTION IS 3 - 4 WEEKS**

RUPP/CAPTIVE AIRE MODEL #	WARREN MODEL #	WARREN TAG #	KW	VOLTAGE/ PHASE	DUCT SIZE WXH	STEPS
EC-1	CBK	WEC1RP3605	36	460/3	16 X 18	2
EC-2	CBK	WEC2RP6905	69	460/3	22.75 X 24	3
EC-3	CBK	WEC3RP8305	83	460/3	30 X 30	3
EC-4	CBK	WEC4RP15505	155	460/3	34 X 36	5
EC-5	CBK	WEC5RP23505	235	460/3	43 X 43	8
EC-11	CBK	WEC11RP1001	9.9	208/1	16 X 18	2
EC-12	CBK	WEC12RP2003	20	208/3	16 X 18	2
EC-14	CBK	WEC14RP2005	20	460/3	16 X 18	4
EC-22	CBK	WEC22RP3603	36	208/3	22.75 X 24	3

WARREN TECHNOLOGY

2050 W 73 ST * PO BOX 5347 * HIALEAH, FL 33014-1347 * TEL 305-556-6933 * FAX 305-557-6157