

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM0502B	VOLTS:	208-1P	240-1P
TAG: BAYHTR1505BRKA	HTR WATTS:	3600	4800
	HTR AMPS:	17.3	20.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B18, B24	23	25	27	30
TEM3A0 B30, B36	25	25	28	30
TEM3A0 C42, C48	25	25	28	30
TEM3A0 C60	30	30	33	35
TEM4A0 B18, B24	23	25	27	30
TEM4A0 B30, C36	25	25	28	30
TEM4A0 C42	27	30	30	30
TEM4A0 C48, C60	30	30	33	35
TEM6A0 B24, B30 / TEM8A0 B24, B30	25	25	29	30
TEM6A0 C36, C42	27	30	30	30
TEM6A0 D48, D60	30	30	34	35
TEM8A0 C36, C42	27	30	30	30
TEM8A0 C48, C60	29	30	32	35
TEM8A0 D48, D60	28	30	31	35

