

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM0504	VOLTS:	208-3P	240-3P
	HTR WATTS:	3600	4800
	HTR AMPS:	10.0	11.5

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B18, B24	14.1	15	16	20
TEM3A0 B30, B36	15.6	20	17.5	20
TEM3A0 C42, C48	15.8	20	17.6	20
TEM3A0 C60	20.4	25	22.3	25
TEM4A0 B18, B24	14.1	15	16	20
TEM4A0 B30, C36	15.8	20	17.6	20
TEM4A0 C42	17.6	20	19.5	20
TEM4A0 C48, C60	20.4	25	22.3	25
TEM6A0 B24, B30 / TEM8A0 B24, B30	16	20	18	20
TEM6A0 C36, C42	18	20	20	20
TEM6A0 D48, D60	21	25	23	25
TEM8A0 C36, C42	17.9	20	19.8	20
TEM8A0 C48, C60	19.5	20	21.4	25
TEM8A0 D48, D60	18.8	20	20.6	25

