

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM0505	VOLTS:		480-3P
	HTR WATTS:		4800
	HTR AMPS:		5.8

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B30, B36			7.3	15
TEM3A0 C42, C48			7.3	15
TEM3A0 C60			7.3	15
TEM4A0 B30, B36, C36, C37			7.3	15
TEM4A0 C42			7.3	15
TEM4A0 C48, C60			7.3	15
TEM6A0 B24, B30			7.3	15
TEM6A0 C36, C42			7.3	15
TEM6A0 C48, D48, D60			7.3	15
TEM8A0 B24, B30, C36, C42, C48, C60, D48, D60			7.3	15

