

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM1002	VOLTS:	208-1P	240-1P
TAG: BAYHTR1510LUG	HTR WATTS:	7200	9600
	HTR AMPS:	34.6	40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B18, B24	45	45	52	60
TEM3A0 B30, B36	46	50	53	60
TEM3A0 C42, C48	47	50	53	60
TEM3A0 C60	51	60	58	60
TEM4A0 B18, B24	45	45	52	60
TEM4A0 B30, C36	46	50	53	60
TEM4A0 C42	48	50	55	60
TEM4A0 C48, C60	51	60	58	60
TEM6A0 B24,B30 / TEM8A0 B24, B30	47	50	54	60
TEM6A0 C36,C42	49	50	55	60
TEM6A0 D48,D60	52	60	59	60
TEM8A0 C36, C42	49	50	55	60
TEM8A0 C48, C60	50	50	57	60
TEM8A0 D48,.D60	50	50	56	60

