

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM1005A	VOLTS:		480-3P
	HTR WATTS:		9600
	HTR AMPS:		11.5

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B30, B36			15.9	20
TEM3A0 C42, C48			16.0	20
TEM3A0 C60			18.3	20
TEM4A0 B30, B36, C36, C37			16	20
TEM4A0 C42			16.9	20
TEM4A0 C48, C60			18.3	20
TEM6A0 B24, B30			16.1	20
TEM6A0 C36, C42			17.1	20
TEM6A0 C48, D48, D60			18.6	20
TEM8A0 B24, B30			16.1	20
TEM8A0 C36, C42			17.1	20
TEM8A0 C48, C60			17.9	20
TEM8A0 D48, D60			17.5	20

