

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM1502B	VOLTS:	208-1P	240-1P
TAG: BAYHTR1515BRK	HTR WATTS:	10800	14400
	HTR AMPS:	34.6-17.3	40-20

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B30, B36	46-22	50-25	53-25	60-25
TEM3A0 C42, C48	47-22	50-25	53-25	60-25
TEM3A0 C60	51-22	60-25	58-25	60-25
TEM4A0 B30, C36	46-22	50-25	53-25	60-25
TEM4A0 C42	48-22	50-25	55-25	60-25
TEM4A0 C48, C60	51-22	60-25	58-25	60-25

