

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM1504V	VOLTS:	208-3P	240-3P
	HTR WATTS:	10800	14400
	HTR AMPS:	30.0	34.6

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM6A0 B30	41	45	46.8	50
TEM6A0 C36, C42	42.9	45	48.6	50
TEM6A0 D48, D60	46	50	51.8	60
TEM8A0 B30	41	50	46	50
TEM8A0 C36, C42	42	45	48	50
TEM8A0 C48, C60	44	45	49	50
TEM8A0 D48, D60	43	45	49	50

