

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM1505	VOLTS:		480-3P
	HTR WATTS:		14400
	HTR AMPS:		17.3

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B30, B36			21.7	25
TEM3A0 C42, C48			21.7	25
TEM3A0 C60			21.7	25
TEM4A0 B30, B36, C36, C37			21.7	25
TEM4A0 C42			21.7	25
TEM4A0 C48, C60			21.7	25
TEM6A0 B30			21.7	25
TEM6A0 C36, C42			21.7	25
TEM6A0 C48, D48, D60			21.7	25
TEM8A0 B30, C36, C42, C48, C60, D48, D60			21.7	25

