INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM2002S	**VOLTS:**	208-1P	240-1P
	HTR WATTS:	14400	19200
	HTR AMPS:	69.2	80

	EQUIPMENT MODEL NO	**MCA**	**MOCP**	**MCA**	**MOCP**
	TEM3A0 C60	96	100	108	110
	TEM4A0 C60	94	100	108	110

WARREN TECHNOLOGY