

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM2002SV	VOLTS:	208 - 1P	240 -1P
	HTR WATTS:	14400	19200
	HTR AMPS:	34.6 - 34.6	40 - 40

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM6A0 C42	92.5	100	105.4	110
TEM6A0 D48,D60	95.1	100	108.5	110
TEM8A0 C36, C42	91.9	100	105.4	110
TEM8A0 C48, C60	93.5	100	107	110
TEM8A0 D48, D60	92.8	100	106.3	110

