



CAUTION: Relays utilize 22VDC coils with AC to DC rectifiers. Do not use relay without rectifier. Replace with factory authorized parts only.

24VAC Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC

FIELD CONNECTION
480VAC
3 ϕ

Model	WEM-0805
Serial #	_____
Tag -	_____
Kilowatts	7.68
Volts-Ph-Hz	480/3Y/60
Control Volts	24.0
Steps	1
Heater Amps	9.2

NOTE :

- * Replace "Service Loop" with SL075A
- ** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
- *** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.
- **** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C. Use copper conductor wiring only.

Control Wiring _____
 Power Wiring _____
 Field Wiring _____