



CAUTION: Relays utilize 22VDC coils with AC to DC rectifiers. Do not use relay without rectifier. Replace with factory authorized parts only.

24VAC Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC

Model	WEM-1005
Serial #	_____
Tag -	_____
Kilowatts	9.6
Volts-Ph-Hz	480/3Y/60
Control Volts	24.0
Steps	1
Heater Amps	11.5

NOTE :

- * Replace "Service Loop" with SL075A
- ** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
- *** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.
- **** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C. Use copper conductor wiring only.

Control Wiring _____

Power Wiring _____

Field Wiring _____

WEM1005

Rev. by : M. REEVES
 Date : 02/27/15

WARREN TECHNOLOGY