



FIELD
CONNECTION
240VAC
3 Ø

CAUTION: Relays utilize 22VDC coils with AC to DC rectifiers. Do not use relay without rectifier. Replace with factory authorized parts only.

24VAC Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC

Model	WFM-1004
Serial #	_____
Tag -	_____
Kilowatts	10.0
Volts-Ph-Hz	240/3/∧/60
Control Volts	24.0
Steps	1
Heater Amps	24.06

NOTE :

** Replace Auto-Reset with Therm-O-Disc type L155-333F

*** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

**** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.

Use copper conductor wiring only.

Control Wiring - - - - -
Power Wiring _____
Field Wiring _____